



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT



APR 26 2013

Gerardo C. Rios, Chief
Permits Office
Air Division
U.S. EPA - Region IX
75 Hawthorne St
San Francisco, CA 94105

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)
Project # 1124511**

Dear Mr. Rios:

The Air Pollution Control Officer has issued Authorities to Construct (S-4-5-10, '-6-9, '-7-9, and '-8-10) with Certificates of Conformity to Tehachapi-Cummings County Water. The project authorizes conversion of lean-burn IC engines from full-time to limited-use operation for Rule 4702 compliance, deletion of a Specific Limiting Condition (SLC), and addition of 40 CFR Part 63 Subpart ZZZZ conditions.

Enclosed are copies of the Authorities to Construct. The application and proposal were sent to US EPA Region IX on April 11, 2013. No comments were received following the District's preliminary decision on this project.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

David Warner
Director of Permit Services

Enclosures
rue

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



San Joaquin Valley

AIR POLLUTION CONTROL DISTRICT



APR 26 2013

Mr. John Martin
Tehachapi-Cummings County Water
PO Box 326
Tehachapi, CA 93561

**Re: Final - Authority to Construct / Certificate of Conformity (Minor Mod)
Project # 1124511**

Dear Mr. Martin:

The Air Pollution Control Officer has issued Authorities to Construct (S-4-5-10, '6-9, '7-9, and '8-10) with Certificates of Conformity to Tehachapi-Cummings County Water. The project authorizes conversion of lean-burn IC engines from full-time to limited-use operation for Rule 4702 compliance, deletion of a Specific Limiting Condition (SLC), and addition of 40 CFR Part 63 Subpart ZZZZ conditions.

Enclosed are the Authorities to Construct and invoice. The application and proposal were sent to US EPA Region IX on April 11, 2013. No comments were received following the District's preliminary decision on this project.

Prior to operating with modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,


David Warner
Director of Permit Services

Enclosures
rue

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585



AUTHORITY TO CONSTRUCT

PERMIT NO: S-4-5-10

ISSUANCE DATE: 04/26/2013

LEGAL OWNER OR OPERATOR: TEHACHAPI-CUMMINGS WATER DIST

MAILING ADDRESS: PO BOX 326
TEHACHAPI, CA 93561

LOCATION: WEST OF TEJON RANCH RD
TEJON RANCH, CA

SECTION: 5 **TOWNSHIP:** 31S **RANGE:** 25E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 1,200 BHP WAUKESHA MODEL 5790GL S/N C-10634-1 NATURAL GAS-FIRED LEAN-BURN IC ENGINE POWERING A WATER PUMP WITH TURBOCHARGER AND INTERCOOLER (ENGINE #1, PLANT #1): LIMIT OPERATING HOURS TO 4,000 HOURS/YEAR FOR RULE 4702 COMPLIANCE, REMOVE ANNUAL EMISSIONS SLC, AND ADD 40 CFR PART 63 SUBPART ZZZZ REMOTE IC ENGINE CONDITIONS

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. Sulfur compound emissions shall not exceed 0.2% by volume, 2000 ppmv, on a dry basis averaged over 15 consecutive minutes. [District Rules 4801 and Kern County Rule 407] Federally Enforceable Through Title V Permit
5. Utilization of this IC engine shall not exceed 1,200 hp, as determined by maintaining the water pumping rate for each unit at or below the following amounts: one IC engine/pump operating - 9.2 cfs, two IC engine/pumps operating - 8.6 cfs, and three or more IC engine/pumps operating - 8.1 cfs. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU **MUST** NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

S-4-5-10 : Apr 26 2013 10:57AM - EDGEHLR : Joint Inspection NOT Required

6. This unit shall only be fired on Public Utility Commission (PUC) regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
7. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
8. IC engine shall be operated no more than 4,000 hours per calendar year. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 65 ppmvd NO_x @ 15% O₂, equivalent to 0.91 g-NO_x/hp-hr, 0.011 g-SO_x/hp-hr, 0.05 g-PM₁₀/hp-hr, 492 ppmvd CO @ 15% O₂, equivalent to 4.18 g-CO/hp-hr, or 309 ppmvd VOC @ 15% O₂, equivalent to 1.50 g-VOC/hp-hr. [District Rules 2201, 4701, and 4702] Federally Enforceable Through Title V Permit
10. Source testing to measure natural gas-combustion NO_x, CO, and VOC emissions from this unit shall be measured not less than once every 24 months, except as follows. Compliance with the NO_x, CO, and VOC emission limits shall be demonstrated by submittal of annual emission test results from a unit or units that represents a specified group of units, provided all of the following requirements are satisfied: the units are located at the same stationary source; the units were produced by the same manufacturer, have the same model number or other manufacturer's designation in common, and have the same rated capacity and operating specification; the units are operated and maintained in a similar manner; and at least 20% of the total number of units are tested during each annual test cycle. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Should any of the representative units exceed the required emission limits, or if the District notifies the operator that the criteria in for representative testing have not been fulfilled, each of the units in the group shall individually demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested units being in violation of this rule. [District Rule 4702] Federally Enforceable Through Title V Permit
12. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The acceptable exhaust gas O₂ range shall be established from manufacturer's information, or by source testing this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
18. The permittee shall install and operate a nonresettable fuel meter and a nonresettable elapsed operating time meter. In lieu of installing a nonresettable fuel meter, the owner or operator may use a non-resettable elapsed operating time meter in conjunction with the engine manufacturer's maximum rated fuel consumption to determine annual fuel usage. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
19. This engine shall be operated and maintained in proper operating condition per the manufacturer's requirements as specified on the Inspection and Maintenance (I&M) plan submitted to the District. [District Rule 4702] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

20. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
21. The permittee shall monitor and record the stack concentration of O₂ at least once every month and the stack concentration of NO_x and O₂ at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O₂ monitors may be allowed if approved by the APCO.] Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
22. If either the O₂ concentration or the NO_x concentration corrected to 15% O₂, as measured by the portable analyzer, is outside the permitted range, the permittee shall return the O₂ and/or NO_x to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue outside the permitted range after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
23. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of O₂ and NO_x measurements, (2) the O₂ concentration in percent and the measured NO_x concentration corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
25. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity (cubic feet of gas or gallons of liquid) of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
26. On and after October 19, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
27. On and after October 19, 2013, IC engine shall only be operated in a sparsely populated area as defined by 40 CFR Part 63, Subpart ZZZZ. Permittee shall conduct a review of the surrounding area every 12 months to determine if nearby population has changed. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
28. On and after October 19, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
29. On and after October 19, 2013, the engine's oil and filter shall be changed every 2,160 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
30. On and after October 19, 2013, the engine's spark plugs shall be inspected every 2,160 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

31. On and after October 19, 2013, the engine's hoses and belts shall be inspected every 2,160 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
32. On and after October 19, 2013, the permittee shall maintain monthly records that include any information necessary to demonstrate compliance with 40 CFR 63, ZZZZ. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
33. On and after October 19, 2013, the permittee shall maintain monthly records of all performance tests and required maintenance performed on the air pollution control and monitoring equipment. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
34. On and after October 19, 2013, the permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
35. On and after October 19, 2013, the permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
36. Permittee shall have on-site for inspection a District-approved Emissions Control Plan for compliance with District Rule 4702. [District Rule 4702] Federally Enforceable Through Title V Permit
37. The permittee shall maintain on file copies of natural gas bills. [District Rules 1070 and 2201] Federally Enforceable Through Title V Permit
38. Permittee shall maintain records of annual operating time. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
39. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-4-6-9

ISSUANCE DATE: 04/26/2013

LEGAL OWNER OR OPERATOR: TEHACHAPI-CUMMINGS WATER DIST

MAILING ADDRESS: PO BOX 326
TEHACHAPI, CA 93561

LOCATION: WEST OF TEJON RANCH RD
TEJON RANCH, CA

SECTION: 5 **TOWNSHIP:** 31S **RANGE:** 25E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 1,070 BHP WAUKESHA MODEL 5790GL S/N 402992 NATURAL GAS-FIRED LEAN-BURN IC ENGINE POWERING A WATER PUMP (IC ENGINE #2, PLANT #1): LIMIT OPERATING HOURS TO 4,000 HOURS/YEAR FOR RULE 4702 COMPLIANCE, REMOVE ANNUAL EMISSIONS SLC, AND ADD 40 CFR PART 63 SUBPART ZZZZ REMOTE IC ENGINE CONDITIONS


CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Utilization of this IC engine shall not exceed 1,070 hp, as determined by maintaining the water pumping rate for each unit at or below the following amounts: one IC engine/pump operating - 8.2 cfs, two IC engine/pumps operating - 7.8 cfs, and three or more IC engine/pumps operating - 7.3 cfs. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO



DAVID WARNER, Director of Permit Services

04-26-13 Apr 26 2013 10:57AM - EDGEHILR : Joint Inspection NOT Required

6. This unit shall only be fired on Public Utility Commission (PUC) regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
7. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
8. IC engine shall be operated no more than 4,000 hours per calendar year. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 65 ppmvd NO_x @ 15% O₂, equivalent to 0.91 g-NO_x/hp-hr, 0.011 g-SO_x/hp-hr, 0.05 g-PM₁₀/hp-hr, 492 ppmvd CO @ 15% O₂, equivalent to 4.18 g-CO/hp-hr, or 309 ppmvd VOC @ 15% O₂, equivalent to 1.50 g-VOC/hp-hr. [District Rules 2201, 4701, and 4702] Federally Enforceable Through Title V Permit
10. Source testing to measure natural gas-combustion NO_x, CO, and VOC emissions from this unit shall be measured not less than once every 24 months, except as follows. Compliance with the NO_x, CO, and VOC emission limits shall be demonstrated by submittal of annual emission test results from a unit or units that represents a specified group of units, provided all of the following requirements are satisfied: the units are located at the same stationary source; the units were produced by the same manufacturer, have the same model number or other manufacturer's designation in common, and have the same rated capacity and operating specification; the units are operated and maintained in a similar manner; and at least 20% of the total number of units are tested during each annual test cycle. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Should any of the representative units exceed the required emission limits, or if the District notifies the operator that the criteria in for representative testing have not been fulfilled, each of the units in the group shall individually demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested units being in violation of this rule. [District Rule 4702] Federally Enforceable Through Title V Permit
12. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The acceptable exhaust gas O₂ range shall be established from manufacturer's information, or by source testing this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
18. This engine shall be operated and maintained in proper operating condition per the manufacturer's requirements as specified on the Inspection and Maintenance (I&M) plan submitted to the District. [District Rule 4702] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of O₂ at least once every month and the stack concentration of NO_x and O₂ at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O₂ monitors may be allowed if approved by the APCO.] Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
21. If either the O₂ concentration or the NO_x concentration corrected to 15% O₂, as measured by the portable analyzer, is outside the permitted range, the permittee shall return the O₂ and/or NO_x to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue outside the permitted range after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of O₂ and NO_x measurements, (2) the O₂ concentration in percent and the measured NO_x concentration corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
24. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity (cubic feet of gas or gallons of liquid) of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
25. On and after October 19, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
26. On and after October 19, 2013, IC engine shall only be operated in a sparsely populated area as defined by 40 CFR Part 63, Subpart ZZZZ. Permittee shall conduct a review of the surrounding area every 12 months to determine if nearby population has changed. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
27. On and after October 19, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
28. On and after October 19, 2013, the engine's oil and filter shall be changed every 2,160 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
29. On and after October 19, 2013, the engine's spark plugs shall be inspected every 2,160 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

30. On and after October 19, 2013, the engine's hoses and belts shall be inspected every 2,160 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
31. On and after October 19, 2013, the permittee shall maintain monthly records that include any information necessary to demonstrate compliance with 40 CFR 63, ZZZZ. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
32. On and after October 19, 2013, the permittee shall maintain monthly records of all performance tests and required maintenance performed on the air pollution control and monitoring equipment. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
33. On and after October 19, 2013, the permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
34. On and after October 19, 2013, the permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
35. Permittee shall have on-site for inspection a District-approved Emissions Control Plan for compliance with District Rule 4702. [District Rule 4702] Federally Enforceable Through Title V Permit
36. The permittee shall maintain on file copies of natural gas bills. [District Rules 1070 and 2201] Federally Enforceable Through Title V Permit
37. Permittee shall maintain records of annual operating time. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-4-7-9

ISSUANCE DATE: 04/26/2013

LEGAL OWNER OR OPERATOR: TEHACHAPI-CUMMINGS WATER DIST

MAILING ADDRESS: PO BOX 326
TEHACHAPI, CA 93561

LOCATION: WEST OF TEJON RANCH RD
TEJON RANCH, CA

SECTION: 5 **TOWNSHIP:** 31S **RANGE:** 25E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 1,070 BHP WAUKESHA MODEL 5790GL S/N 402993 NATURAL GAS-FIRED LEAN-BURN IC ENGINE POWERING A WATER PUMP (ENGINE #3, PLANT #1): LIMIT OPERATING HOURS TO 4,000 HOURS/YEAR FOR RULE 4702 COMPLIANCE, REMOVE ANNUAL EMISSIONS SLC, AND ADD 40 CFR PART 63 SUBPART ZZZZ REMOTE IC ENGINE CONDITIONS

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Utilization of this IC engine shall not exceed 1,070 hp, as determined by maintaining the water pumping rate for each unit at or below the following amounts: one IC engine/pump operating - 8.2 cfs, two IC engine/pumps operating - 7.8 cfs, and three or more IC engine/pumps operating - 7.3 cfs. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

SA-479 Apr 26 2013 10:57AM - EDGEHILL : Joint Inspection NOT Required

6. This unit shall only be fired on Public Utility Commission (PUC) regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
7. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
8. IC engine shall be operated no more than 4,000 hours per calendar year. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 65 ppmvd NOx @ 15% O2, equivalent to 0.91 g-NOx/hp-hr, 0.011 g-SOx/hp-hr, 0.05 g-PM10/hp-hr, 492 ppmvd CO @ 15% O2, equivalent to 4.18 g-CO/hp-hr, or 309 ppmvd VOC @ 15% O2, equivalent to 1.50 g-VOC/hp-hr. [District Rules 2201, 4701, and 4702] Federally Enforceable Through Title V Permit
10. Source testing to measure natural gas-combustion NOx, CO, and VOC emissions from this unit shall be measured not less than once every 24 months, except as follows. Compliance with the NOx, CO, and VOC emission limits shall be demonstrated by submittal of annual emission test results from a unit or units that represents a specified group of units, provided all of the following requirements are satisfied: the units are located at the same stationary source; the units were produced by the same manufacturer, have the same model number or other manufacturer's designation in common, and have the same rated capacity and operating specification; the units are operated and maintained in a similar manner; and at least 20% of the total number of units are tested during each annual test cycle. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Should any of the representative units exceed the required emission limits, or if the District notifies the operator that the criteria in for representative testing have not been fulfilled, each of the units in the group shall individually demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested units being in violation of this rule. [District Rule 4702] Federally Enforceable Through Title V Permit
12. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NOx, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The acceptable exhaust gas O2 range shall be established from manufacturer's information, or by source testing this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
18. This engine shall be operated and maintained in proper operating condition per the manufacturer's requirements as specified on the Inspection and Maintenance (I&M) plan submitted to the District. [District Rule 4702] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of O₂ at least once every month and the stack concentration of NO_x and O₂ at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O₂ monitors may be allowed if approved by the APCO.] Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
21. If either the O₂ concentration or the NO_x concentration corrected to 15% O₂, as measured by the portable analyzer, is outside the permitted range, the permittee shall return the O₂ and/or NO_x to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue outside the permitted range after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of O₂ and NO_x measurements, (2) the O₂ concentration in percent and the measured NO_x concentration corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
24. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity (cubic feet of gas or gallons of liquid) of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
25. On and after October 19, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
26. On and after October 19, 2013, IC engine shall only be operated in a sparsely populated area as defined by 40 CFR Part 63, Subpart ZZZZ. Permittee shall conduct a review of the surrounding area every 12 months to determine if nearby population has changed. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
27. On and after October 19, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
28. On and after October 19, 2013, the engine's oil and filter shall be changed every 2,160 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
29. On and after October 19, 2013, the engine's spark plugs shall be inspected every 2,160 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

30. On and after October 19, 2013, the engine's hoses and belts shall be inspected every 2,160 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
31. On and after October 19, 2013, the permittee shall maintain monthly records that include any information necessary to demonstrate compliance with 40 CFR 63, ZZZZ. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
32. On and after October 19, 2013, the permittee shall maintain monthly records of all performance tests and required maintenance performed on the air pollution control and monitoring equipment. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
33. On and after October 19, 2013, the permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
34. On and after October 19, 2013, the permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
35. Permittee shall have on-site for inspection a District-approved Emissions Control Plan for compliance with District Rule 4702. [District Rule 4702] Federally Enforceable Through Title V Permit
36. The permittee shall maintain on file copies of natural gas bills. [District Rules 1070 and 2201] Federally Enforceable Through Title V Permit
37. Permittee shall maintain records of annual operating time. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit



AUTHORITY TO CONSTRUCT

PERMIT NO: S-4-8-10

ISSUANCE DATE: 04/26/2013

LEGAL OWNER OR OPERATOR: TEHACHAPI-CUMMINGS WATER DIST

MAILING ADDRESS: PO BOX 326
TEHACHAPI, CA 93561

LOCATION: WEST OF TEJON RANCH RD
TEJON RANCH, CA

SECTION: 5 **TOWNSHIP:** 31S **RANGE:** 25E

EQUIPMENT DESCRIPTION:

MODIFICATION OF 1,070 BHP WAUKESHA MODEL 5790GL S/N C11010/1 NATURAL GAS-FIRED LEAN-BURN IC ENGINE POWERING A WATER PUMP (ENGINE #4, PLANT #1): LIMIT OPERATING HOURS TO 4,000 HOURS/YEAR FOR RULE 4702 COMPLIANCE, REMOVE ANNUAL EMISSIONS SLC, AND ADD 40 CFR PART 63 SUBPART ZZZZ REMOTE IC ENGINE CONDITIONS

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702] Federally Enforceable Through Title V Permit
5. Utilization of this IC engine shall not exceed 1,070 hp, as determined by maintaining the water pumping rate for each unit at or below the following amounts: one IC engine/pump operating - 8.2 cfs, two IC engine/pumps operating - 7.8 cfs, and three or more IC engine/pumps operating - 7.3 cfs. [District Rule 2201] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (661) 392-5500 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Seyed Sadredin, Executive Director / APCO

DAVID WARNER, Director of Permit Services

APC-40: Apr 26 2013 10:57AM - EDGEHILR - Joint Inspection NOT Required

6. This unit shall only be fired on Public Utility Commission (PUC) regulated natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
7. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
8. IC engine shall be operated no more than 4,000 hours per calendar year. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
9. Emissions from this IC engine shall not exceed any of the following limits: 65 ppmvd NO_x @ 15% O₂, equivalent to 0.91 g-NO_x/hp-hr, 0.011 g-SO_x/hp-hr, 0.05 g-PM₁₀/hp-hr, 492 ppmvd CO @ 15% O₂, equivalent to 4.18 g-CO/hp-hr, or 309 ppmvd VOC @ 15% O₂, equivalent to 1.50 g-VOC/hp-hr. [District Rules 2201, 4701, and 4702] Federally Enforceable Through Title V Permit
10. Source testing to measure natural gas-combustion NO_x, CO, and VOC emissions from this unit shall be measured not less than once every 24 months, except as follows. Compliance with the NO_x, CO, and VOC emission limits shall be demonstrated by submittal of annual emission test results from a unit or units that represents a specified group of units, provided all of the following requirements are satisfied: the units are located at the same stationary source; the units were produced by the same manufacturer, have the same model number or other manufacturer's designation in common, and have the same rated capacity and operating specification; the units are operated and maintained in a similar manner; and at least 20% of the total number of units are tested during each annual test cycle. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
11. Should any of the representative units exceed the required emission limits, or if the District notifies the operator that the criteria in for representative testing have not been fulfilled, each of the units in the group shall individually demonstrate compliance by emissions testing. Failure to complete emissions testing within 90 days of the failed test shall result in the untested units being in violation of this rule. [District Rule 4702] Federally Enforceable Through Title V Permit
12. Emissions source testing shall be conducted with the engine operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
13. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. VOC emissions shall be reported as methane. VOC, NO_x, and CO concentrations shall be reported in ppmv, corrected to 15% oxygen. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NO_x (ppmv) - EPA Method 7E or ARB Method 100, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and VOC (ppmv) - EPA Method 25 or EPA Method 18 referenced as methane. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The acceptable exhaust gas O₂ range shall be established from manufacturer's information, or by source testing this unit. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
18. This engine shall be operated and maintained in proper operating condition per the manufacturer's requirements as specified on the Inspection and Maintenance (I&M) plan submitted to the District. [District Rule 4702] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

19. The permittee shall update the I&M plan for this engine prior to any planned change in operation. The permittee must notify the District no later than seven days after changing the I&M plan and must submit an updated I&M plan to the APCO for approval no later than 14 days after the change. The date and time of the change to the I&M plan shall be recorded in the engine's operating log. For modifications, the revised I&M plan shall be submitted to and approved by the APCO prior to issuance of the Permit to Operate. The permittee may request a change to the I&M plan at any time. [District Rule 4702] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of O₂ at least once every month and the stack concentration of NO_x and O₂ at least once every calendar quarter (in which a source test is not performed) using a portable emission monitor that meets District specifications. [In-stack O₂ monitors may be allowed if approved by the APCO.] Monitoring shall not be required if the engine is not in operation, i.e. the engine need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the engine unless monitoring has been performed within the last month. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
21. If either the O₂ concentration or the NO_x concentration corrected to 15% O₂, as measured by the portable analyzer, is outside the permitted range, the permittee shall return the O₂ and/or NO_x to within the acceptable range as soon as possible, but no longer than 8 hours after detection. If the portable analyzer readings continue outside the permitted range after 8 hours, the permittee shall notify the District within the following 1 hour, and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of O₂ and NO_x measurements, (2) the O₂ concentration in percent and the measured NO_x concentration corrected to 15% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
24. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type and quantity (cubic feet of gas or gallons of liquid) of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
25. On and after October 19, 2013, the engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
26. On and after October 19, 2013, IC engine shall only be operated in a sparsely populated area as defined by 40 CFR Part 63, Subpart ZZZZ. Permittee shall conduct a review of the surrounding area every 12 months to determine if nearby population has changed. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
27. On and after October 19, 2013, the permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
28. On and after October 19, 2013, the engine's oil and filter shall be changed every 2,160 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
29. On and after October 19, 2013, the engine's spark plugs shall be inspected every 2,160 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

30. On and after October 19, 2013, the engine's hoses and belts shall be inspected every 2,160 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
31. On and after October 19, 2013, the permittee shall maintain monthly records that include any information necessary to demonstrate compliance with 40 CFR 63, ZZZZ. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
32. On and after October 19, 2013, the permittee shall maintain monthly records of all performance tests and required maintenance performed on the air pollution control and monitoring equipment. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
33. On and after October 19, 2013, the permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
34. On and after October 19, 2013, the permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
35. Permittee shall have on-site for inspection a District-approved Emissions Control Plan for compliance with District Rule 4702. [District Rule 4702] Federally Enforceable Through Title V Permit
36. The permittee shall maintain on file copies of natural gas bills. [District Rules 1070 and 2201] Federally Enforceable Through Title V Permit
37. Permittee shall maintain records of annual operating time. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit